



County of Riverside DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234
www.rivcoeh.org

FACILITY NAME LITTLE CAESAR'S PIZZA #5855					DATE 9/17/2019	TIME IN 2:00 PM	TIME OUT 2:30 PM
LOCATION 1336 E FLORIDA AVE, Hemet, CA 92544						RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Little Caesars Enterprises					E-MAIL Not Specified		
PERMIT # PR0004974	EXPIRATION DATE 09/30/2019	SERVICE Facility closure	FACILITY PHONE (313)983-6000	PE 2620	DISTRICT 0011	INSPECTOR NAME Beatriz Cornejo	

Inspector Observations:

Complaint investigation (CO0070601) due to Department of Environmental Health Emergency Response notification of a burst pipe from Hemet Fire Department. Per person in charge, the pipe for the fire sprinkler directly in front of the hood canopy burst overnight on 9/16/19. Facility had flooding on the floor below the affected sprinkler. Facility completed all clean up of the floors and removed any contaminated utensils or food prior to the inspector investigation. Facility has self-closed pending a repair of the affected fire sprinkler. Facility must ensure that a repair of the fire sprinkler is completed prior to re-opening of facility and pizza oven directly in front of the affected fire sprinkler must be cleaned and sanitized prior to use. Provide proof of repair to BCCornejo@Rivco.org prior to re-opening of facility. Routine inspection for facility had been completed by J. Roy on 8/12/19.

Signature

Laura Davila
Person in Charge
09/17/2019

Beatriz Cornejo
Environmental Health Specialist
09/17/2019